



Certificate of Compliance

Certificate: 70051432 (205078)

Master Contract: 205078

Project: 70051432

Date Issued: 2016-06-30

Issued to: Analog Devices Inc.
804 Woburn St
Wilmington, Massachusetts 01887-3462
USA

Attention: Donal O'Sullivan

The products listed below are eligible to bear the CSA Mark shown with adjacent indicator ▲



Issued by: Martin Buchanan
Martin Buchanan, P. Eng.

PRODUCTS

Component Acceptance of Optoisolator Like Magnetic Coupling Devices:

Device (SOIC 8W RI package)	Ratings		Clauses of Standard/Notice	Internal		External
	kV	°C		Creepage (mm)	Dist Thru (mm)	Creep/Clear (mm)
ADuM210N0BRIZ ADuM210N1BRIZ ADuM210N0WBRIZ ADuM210N1WBRIZ	5.0	125	CSA CA5A, 14-13 Tbl 35, 6.2.1.1, 6.2.1.1/6.2.10, 6.8.1.1 60950-1-07+A1+A2 2.10.3.3, 2.10.4.2, 2.10.4.3, 2.10.5.4a, 2.10.11, 4.5.2, 5.2 61010-1-12+A1 K.3, K.4, 6.7.1.3, 6.7.2.2.2 A.17, K.6x1.6, K.7x1.6, 10 60601-1:14 8.5.5.1, 8.8.2, 8.8.3x1.6, 8.9.3.2, 8.9.3.4, 8.9.1.15, 8.9.1.7 IEC 60950-1 2nd Ed., +A1+A2 2.10.3.3, 2.10.4.2, 2.10.4.3, 2.10.5.4a, 2.10.11, 4.5.2, 5.2 61010-1 3 rd Ed K.3, K.4, 6.7.1.3, 6.7.2.2.2 A.17, K.6x1.6, K.7x1.6, 10 60601-1 Ed.3+A1 8.5.5.1, 8.8.2, 8.8.3x1.6, 8.9.3.2, 8.9.3.4, 8.9.1.15, 8.9.1.7 EN	-	-	8.3



Certificate: 70051432
Project: 70051432

Master Contract: 205078
Date Issued: 2016-06-30

Device (SOIC 8W RI package)	Ratings		Clauses of Standard/Notice	Internal		External
	kV	°C		Creepage (mm)	Dist Thru (mm)	Creep/Clear (mm)
			60950-1:2006+A1+A12+A2 2.10.3.3, 2.10.4.2, 2.10.4.3, 2.10.5.4a, 2.10.11, 4.5.2, 5.2			

where Z, if used, indicates the lead-free version. Suffix EP at the end of the base part number indicates lower extended temperature capability to -55C with a NiPdAu lead finish. Further suffix letters or digits differentiate shipping package formats.

Notes:

1. These devices meet basic insulation requirements for 830Vrms for CSA 60950-1-07+A1+A2 and IEC 60950-1 2nd Ed.+A1+A2.
2. These devices meet reinforced insulation requirements for 415Vrms for CSA 60950-1-07+A1+A2 and IEC 60950-1 2nd Ed.+A1+A2. (pollution degree 2, material group III)
3. For CSA 61010-1-12+A1 and IEC 61010-1 3rd Ed. for 600Vrms, overvoltage category IV for basic and 300Vrms, overvoltage category III for reinforced insulation, the devices meet clauses K.3, K.4, 6.7.1.3, 6.7.2.2.2 A.17, K.6x1.6, K.7x1.6, 10. The risk management process is not applicable to these clauses. (pollution degree 2, material group III)
4. For CSA 60601-1:14 and IEC60601-1 Ed.3+A1 for 2 MOPP for 250Vrms, the devices meet clauses 8.5.5.1, 8.8.2, 8.8.3x1.6, 8.9.3.2, 8.9.3.4, 8.9.1.15, 8.9.1.7. The risk management process is not applicable to these clauses.
4. Case material: 575Vrms with erosion depth 0.079mm, meets material group II.
5. Evaluated by thermal cycling and other tests for a temperature rating of 125C.
6. The creepage and clearance has been evaluated for altitudes ≤ 2000m, in pollution degree 2 and overvoltage category II except where specified above. (pollution degree 2, material group III).

These devices are Component Accepted as components for use in other Certified equipment where the suitability of the combination shall be determined by investigation in the final application.

APPLICABLE REQUIREMENTS

- Component Acceptance Notice 5A (CA 5A) - Announcement of Extension of the Component Acceptance Service for Optocouplers and Related Devices
- CAN/CSA-C22.2 No 14-13 - Industrial Control Equipment
- CAN/CSA-C22.2 No 60950-1-07+A1+A2 - Information Technology Equipment - Safety - Part 1: General Requirements (Bi-national Standard, with UL 60950-1)
- IEC 60950-1 2nd Ed.+A1+A2 - Information Technology Equipment - Safety - Part 1: General Requirements
- EN 60950-1:2006+A1+A12+A2 - Information Technology Equipment - Safety - Part 1: General Requirements

- Clauses K.3, K.4, 6.7.1.3, 6.7.2.2.2 A.17, K.6x1.6, K.7x1.6, 10
of
CAN/CSA-C22.2 No. 61010-1-12+A1 2015 - Safety Requirements for Electrical Equipment for Measurement, Control and Laboratory Use - Part 1: General Requirements



Certificate: 70051432

Project: 70051432

Master Contract: 205078

Date Issued: 2016-06-30

(Tri-national standard, with UL 61010-1 Ed. 3 and ANSI/ISA-61010-1 (82.02.01)

and

IEC 61010-1:2010 3rd Ed.

- Safety Requirements for Electrical Equipment for Measurement, Control and Laboratory Use - Part 1: General Requirements

Clauses 8.5.5.1, 8.8.2, 8.8.3x1.6, 8.9.3.2, 8.9.3.4, 8.9.1.15, 8.9.1.7

of

CAN/CSA C22.2 60601-1:14

- Medical Electrical Equipment Part 1: General requirements for basic safety and general performance (Adopted IEC60601-1:2005 Edition 3.0 +Amendment 1, 2012-07, MOD)

and

IEC60601-1:2005 Ed 3.0+A1

- Medical Electrical Equipment Part 1: General requirements for basic safety and general performance